



**AHMEDABAD MUNICIPAL CORPORATION**  
**FIRE AND EMERGENCY SERVICES DEPARTMENT**

DANAPITH FIRE STATION (HEADQUARTERS), NR.AMC OFFICE, DANAPITH, AHMEDABAD

NOC Number: NOC205017072021

Category: School

NOC Issue Date: 29/09/2021

**NO OBJECTION CERTIFICATE**

This is to certify that management of M/s **SHANTI ASIATIC SCHOOL** located at **NR. BALIYADEV TEMPLE, OPP. GRAM PANCHAYAT, B/H RAF CAMP, VASTRAL, AHMEDABAD 382418** has installed necessary Fire Protection Equipments mentioned below.

**Hydrant System With**

• Main Pump	-( 1 Nos.)
• Hose Box with Hose	-( 2 Nos.)
• Hydrant Point / Valve	-( 2 Nos.)
• Fire Bridge Inlet (2/4 Way)	-( 1 Nos.)
• Hose Reel	-( 9 Nos.)
• Short Branch	-( 2 Nos.)
• Sprinklers System Installed	Yes
• Heat Detection System Installed	Yes
• Manual Call Point	-( 9 Nos.)
• Fire Alarm System Installed	Yes

**Fire Extinguishers**

• 6 Kg. Capacity ABC Type	-( 20 Nos.)
• 4.5 Kg. Capacity Co2 Type	-( 8 Nos.)

All the Fire Protection Equipments installed shall be maintained in working order throughout the validity period of this certificate.

**This Certificate is valid for THREE YEAR from the date of issue.**



(Rajesh Bhatt)  
Chief Fire Officer (I/c)  
Ahmedabad Municipal Corporation